

Intertek

REPORT NUMBER: 100566493SAT-001A
ORIGINAL ISSUE DATE: December 13, 2011
REVISED DATE:

EVALUATION CENTER
Intertek Testing Services NA Inc.
16015 Shady Falls Road
Elmendorf, TX 78112

RENDERED TO

Extrutech Plastics Inc.
5902 West Custer Street
Manitowac, WI 54220

Report of Testing "ExtruCrete Panel – Plastic concrete slab" for compliance with the applicable requirements of the following criteria: ASTM E84-11b TEST FOR SURFACE BURNING CHARACTERISTICS OF BUILDING MATERIALS (UL 723, UBC 8-1, NFPA 255)

TEST REPORT

ABSTRACT

Specimen I. D. "ExtruCrete Panel – Plastic concrete slab"

Test Standard: ASTM E84-11b TEST FOR SURFACE BURNING
CHARACTERISTICS OF BUILDING MATERIALS (UL
723, UBC 8-1, NFPA 255)

Test Date: December 7, 2011

Client: Extrutech Plastics Inc.

Test Results:

FLAME SPREAD INDEX	10
SMOKE DEVELOPED INDEX	300

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of the report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Darrell Gonzales

Darrell Gonzales
Technician 2

December 13, 2011

Reviewed and approved:

Servando Romo

Servando Romo

December 14, 2011

Intertek